



NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance

for Weighing and Measuring Devices

For:

Load Cell
Single Point
Models: L6D and L6D-R1 Series
 n_{max} : 5 000, Class III, Single/Multiple Cell
Capacity: 2.5kg to 50 kg
Accuracy Class: III

***Submitted By: Contact Info. Updated October 2015**

Zemic USA, Inc.
9252 Hall Road
Downey, CA 90241
Tel: 562-923-6431
Fax: 562-923-6436
Contact: Samuel Chang
Email: sedjc@aol.com
Web site: www.zemic.us.com

Standard Features and Options

The specific load cell capacities, v_{min} values, and minimum dead loads covered by this Certificate are listed in page two.

Model L6D (350 Ω Bridge Nom), wiring color code: Red(+Ex), Black(-Ex), Green(+Signal), White(-Signal)


Model L6D-R1 (1000 Ω Bridge Nom), wiring code: Red(+Ex), White(-Ex), Green(+Signal), Blue(-Signal)


Standard Features:

- Nominal Output: 2.0 mV/V
- Aluminum Material
- 4 Wire Design

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.


Tim Tyson
Chairman, NCWM, Inc.


Randy Jennings
Chairman, National Type Evaluation Program Committee
Issued: February 4, 2011

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



Zemic USA, Inc.

Load Cell / L6D and L6D-R1 Series

Model	Capacity	V_{\min} Class III Single cell, n=5000	V_{\min} Class III Multiple cell, n=5000	Minimum Dead Load
L6D & L6D-R1	2.5 kg	0.0002 kg	0.0002 kg	0 kg
L6D & L6D-R1	3 kg*	0.0002 kg	0.0002 kg	0 kg
L6D & L6D-R1	5 kg	0.0003 kg	0.0003 kg	0 kg
L6D & L6D-R1	6kg	0.0004 kg	0.0004 kg	0 kg
L6D & L6D-R1	8 kg	0.0005 kg	0.0005 kg	0 kg
L6D & L6D-R1	10 kg	0.0007 kg	0.0007 kg	0 kg
L6D & L6D-R1	15 kg	0.0010kg	0.0010kg	0 kg
L6D & L6D-R1	20 kg*	0.0013 kg	0.0013 kg	0 kg
L6D & L6D-R1	30 kg	0.0020 kg	0.0020 kg	0 kg
L6D & L6D-R1	35 kg	0.0023 kg	0.0023 kg	0 kg
L6D & L6D-R1	40 kg	0.0026 kg	0.0026 kg	0 kg
L6D & L6D-R1	50 kg	0.0033 kg	0.0033 kg	0 kg

*2 load cells tested

Application: The load cells may be used in Class III scales for single and multiple cell applications consistent with the model designations, number of scale divisions, and parameters specified in this certificate. Load cells of a given accuracy class may be used in applications with lower accuracy class requirements provided the number of scale divisions, the v_{\min} value, and temperature range are suitable for the application. The manufacturer may market the load cell with fewer divisions (n_{\max}) and with greater v_{\min} values than those listed on the certificate. However, the load cells must be marked with the appropriate n_{\max} and v_{\min} for which the load cell may be used.

Identification: A pressure sensitive identification label located on the cell, states manufacturer name, model number, serial number, rated capacity, rated output, V_{\min} , class, CC number and country of origin. Other pertinent information will be specified on the Calibration Certificate accompanying the cell.

Test Conditions: Two Model L6D (3kg and 20 kg capacity) load cells were tested by the NMI Certain B.V. at The Netherlands facility. Testing was conducted in accordance with the OIML DoMC Mutual Acceptance Arrangement, signed by the NCWM as a utilizing participant for load cell testing. Testing was conducted using deadweights as the reference standard. The load cells were tested over a temperature range of -10 °C to 40 °C with tests run on each cell at each temperature. The temperature effect on zero was measured and a time dependence (creep) test was performed. The barometric pressure test was performed on both cells. The data were analyzed for single and multiple load cell applications. OIML R60 selection criteria was used to determine cells tested.

Evaluated By: A.C Pauwels, C. Bontenbal, R. Scholten (NMI)

Type Evaluation Criteria Used: NIST, Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices, 2010. NCWM, Publication 14: Weighing Devices, 2010.

Conclusion: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: J. Truex (NCWM)



Zemic USA, Inc.

Load Cell / L6D and L6D-R1 Series

Example of Device:



Model L6D / L6D-R1

